

Tabuľka č. 7 - Bilancia potreby elektrickej energie

UPC	FPB	Funkčné využitie územia	Merná jednotka		Príkon v kW/b.j.	Príkon v kW/m ²	Súdobosť (β)	NO	VO
			Bytová a ubytov. Jednotka	Podlaž. plocha v m ²				r. 2030	r. 2045
								Pp v kW	Pp v kW
1	2	3	4	5	6	7	8	9	10
1	1.1	OÚ / IBV	24		11		0,39	103	
	1.2	OÚ / IBV	13		11		0,45	64	
	1.3A	OÚ / IBV	25		11		0,39	107	
	1.4	VÚ / PRV	26		11		0,39	112	
	1.4	VÚ / PRV		7 032		0,05		352	
	1.5	OÚ / IBV	2		11		0,78	17	
	1.6	OÚ / IBV	8		11		0,51	45	
	1.7	OÚ / IBV	10		11		0,48	53	
	1.8	RÚ / INT		2 280		0,025			57
	1.9	OÚ / IBV	7		11		0,53	41	
	1.10	OÚ / IBV	13		11		0,42	60	
	1.11	OÚ / IBV	6		11		0,55	36	
	1.12A	OÚ / HBV	80		11		0,32	282	
	1.12B	OÚ / HBV	12		11		0,42		55
	1.13A	OÚ / IBV	6		11		0,49	32	
	1.13B	OÚ / IBV	3		11		0,49		16
	1.14	OÚ / IBV	25		11		0,39	107	
	1.15	OV		450		0,025		11	
	1.16	OÚ / IBV	12		11		0,46	61	
	1.17	OÚ / IBV	11		11		0,47	57	
	1.18	OÚ / IBV	23		11		0,40	101	
	1.19	OÚ / IBV	4		11		0,62	27	
	1.20	OÚ / HBV	38		11		0,36	150	
	1.21	OÚ / IBV	34		11		0,37		138
	1.22	OÚ / IBV	11		11		0,47		57
1.23	Pohrebisko								
1.25	OÚ / IBV	31		11		0,38	130		
Spolu (za bývanie a vybavenosť,								1 948	324
Verejné osvetlenie				3%				58	10
Celkom potreba el. energie v kW								2 007	334