

**Tabuľka č. 8 - Návrh transformačných staníc**

| UPC                            | FPB      | Funkčné využitie územia | Merná jednotka            |                                   | NO           | VO         | NO            | VO          | Poznámka                 |               |    |
|--------------------------------|----------|-------------------------|---------------------------|-----------------------------------|--------------|------------|---------------|-------------|--------------------------|---------------|----|
|                                |          |                         | Bytová a ubytov. Jednotka | Zastavaná plocha v m <sup>2</sup> | r. 2030      | r. 2045    | r. 2030       | r. 2045     |                          |               |    |
| 1                              | 2        | 3                       |                           |                                   | 4            | 5          | 9             | 10          | 11                       | 12            | 13 |
| 1                              | 1.1      | OÚ / IBV                | 24                        |                                   | 103          |            |               |             |                          |               |    |
|                                | 1.2      | OÚ / IBV                | 13                        |                                   | 64           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 167        |               | TSN1 1x250  |                          | nová          |    |
|                                | 1.3      | OÚ / IBV                | 25                        |                                   | 107          |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 107        |               | TS6 250/400 |                          | rekonštrukcia |    |
|                                | 1.4      | VÚ / PRV                | 26                        |                                   | 112          |            |               |             |                          |               |    |
|                                | 1.4      | VÚ / PRV                |                           | 7 032                             | 352          |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 463        |               | TSN2 1x400  |                          | nová          |    |
|                                | 1.5      | OÚ / IBV                | 2                         |                                   | 17           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 17         |               | TS1         |                          | bez zásahu    |    |
|                                | 1.6      | OÚ / IBV                | 8                         |                                   | 45           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 45         |               | TS4 160/250 |                          | rekonštrukcia |    |
|                                | 1.7      | OÚ / IBV                | 10                        |                                   | 53           |            |               |             |                          |               |    |
|                                | 1.8      | RÚ / INT                |                           | 2 280                             |              |            | 57            |             |                          |               |    |
|                                | 1.9      | OÚ / IBV                | 7                         |                                   | 41           |            |               |             |                          |               |    |
|                                | 1.19     | OÚ / IBV                | 4                         |                                   | 27           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 121        | 57            | TSN3 1x250  |                          | nová          |    |
|                                | 1.10     | OÚ / IBV                | 13                        |                                   | 60           |            |               |             |                          |               |    |
|                                | 1.17     | OÚ / IBV                | 11                        |                                   | 57           |            |               |             |                          |               |    |
|                                | 1.18     | OÚ / IBV                | 23                        |                                   | 101          |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 218        |               | TS8 250/630 |                          | rekonštrukcia |    |
|                                | 1.14     | OÚ / IBV                | 25                        |                                   | 107          |            |               |             |                          |               |    |
|                                | 1.25     | OÚ / IBV                | 31                        |                                   | 130          |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 107        |               | TSN4 1x160  |                          | nová          |    |
|                                | 1.15     | OV                      |                           | 450                               | 11           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 11         |               | TS5         |                          | bez zásahu    |    |
|                                | 1.16     | OÚ / IBV                | 12                        |                                   | 61           |            |               |             |                          |               |    |
|                                |          |                         |                           |                                   | Σ            | 61         |               | TS3 250/400 |                          | rekonštrukcia |    |
|                                | 1.11     | OÚ / IBV                | 6                         |                                   | 36           |            |               |             |                          |               |    |
|                                | 1.12A    | OÚ / HBV                | 80                        |                                   | 282          |            |               |             |                          |               |    |
| 1.12B                          | OÚ / HBV | 12                      |                           |                                   |              | 55         |               |             |                          |               |    |
| 1.13A                          | OÚ / IBV | 6                       |                           | 32                                |              |            |               |             |                          |               |    |
| 1.13B                          | OÚ / IBV | 3                       |                           |                                   |              | 16         |               |             |                          |               |    |
| 1.20                           | OÚ / HBV | 38                      |                           | 150                               |              |            |               |             |                          |               |    |
|                                |          |                         |                           | Σ                                 | 501          | 72         | TS7 250/2x400 |             | rekonštrukcia, prekládka |               |    |
| 1.21                           | OÚ / IBV | 34                      |                           |                                   |              | 138        |               |             |                          |               |    |
|                                |          |                         |                           | Σ                                 |              | 138        |               | TSN5 1x160  |                          | nová          |    |
| 1.22                           | OÚ / IBV | 11                      |                           |                                   |              | 57         |               |             |                          |               |    |
|                                |          |                         |                           | Σ                                 |              | 57         |               | TSN3 1x250  |                          |               |    |
| <b>Celkový výpočtový výkon</b> |          |                         |                           |                                   | <b>1 819</b> | <b>519</b> |               |             |                          |               |    |